

DYNASTY X-FLUSH

Bio-Remediation Bacterial Digestant



Form: Liquid

Color: Milky Blue

Odor: Pleasant

pH: 6.50 - 7.50

Solubility (in water): Soluble
(in mineral spirits): Insoluble

VOC Content (% by weight): N/D

Flash Point (ASTM D-7821): None

Specific Gravity: 1.01 ± 0.01 g/cm³

Density: 8.43 ± 0.05 lbs/gal

Storage Stability (at 70°F): 1 year

<u>Ingredients</u>	<u>C.A.S. #</u>
Water.....	7732-18-5
Genes Bacillus	68038-68-6
Perfume	No CAS Number
Preservative.....	No CAS Number
Blue Dye	No CAS Number

Use in...	
•	X-Ray Drain Systems
•	CAT Scan Drain Systems
•	MRI Drain Systems
•	Laboratory Drain Systems
•	Hospitals
•	Medical Centers/Clinics
•	Dentist Offices
•	Veterinary Clinics

DIRECTIONS: For X-ray Drains and Sinks: Add an initial treatment of 1 gallon of DYNASTY X-FLUSH, then 30 ounces per day for six weeks. After six weeks, DYNASTY X-FLUSH addition may be reduced to 20 ounces per day. Addition of DYNASTY X-FLUSH should be at the end of the day or during periods of lowest flow through drains. DYNASTY X-FLUSH may be used through the “Bio-Drain Pump” which dispenses product at a rate of 5 ounces per minute. Use the chart below as a guide for using DYNASTY X-FLUSH through the “Bio-Drain Pump.”

<u>Pipe Size</u>	<u>Dosage</u>	<u>Bio-Drain Pump Run Time</u>
2 inches	5 ounces per day	1 minute per day
4 inches	10 ounces per day	2 minutes per day
6 inches	15 ounces per day	3 minutes per day
8 inches	20 ounces per day	4 minutes per day

HMIS			NFPA		
	Severe 4	Extreme			
Health.....0	Serious 3	High	Health.....0		
Flammability.....0	Moderate 2	Moderate	Flammability.....0		
Reactivity.....0	Slight 1	Slight	Reactivity.....0		
Personal Protection..... None	Minimal 0	Insignificant	Special Precautions..... None		